

Diablo Canyon Power Plant Digital Process Protection System Replacement Overview

Kenneth J. Schrader

Pacific Gas & Electric Co.
PO Box 56
Avila Beach, CA 93424
kjse@pge.com

John W. Hefler

ALTRAN
555 Montgomery Street, Suite 1100
San Francisco, CA 94111
John.hefler@altran.com

Edward (Ted) L. Quinn

Technology Resources
23292 Pompeii Drive
Dana Point, CA 92629
tedquinn@cox.net

ABSTRACT

Diablo Canyon Power Plant (DCPP) is replacing the existing digital Westinghouse Eagle 21 Process Protection System (PPS) to address obsolescence issues. Eagle 21 was installed in 1994 to replace the original analog Westinghouse 7100 PPS. The PPS replacement design is based on a combination of the Invensys Tricon V10 programmable logic controller and the Westinghouse Advanced Logic System field programmable gate array digital instrumentation and control devices.

The License Amendment for replacement of the Eagle 21 PPS was submitted to the NRC on October 26, 2011. Key to submittal of the PPS replacement LAR was resolution of the need for Diversity and Defense-in-Depth (D3) in the replacement design to mitigate the potential for a common design error to disable redundant channels of the protection systems through common-cause failure (CCF). The PG&E PPS Replacement Project D3 Assessment Topical Report was submitted to the NRC in April, 2010, and approved in April, 2011.

This paper discusses the architecture of the PPS replacement design and the methodology by which PG&E assessed the diversity requirements of the Diablo Canyon Power Plant (DCPP) digital PPS relative to current regulations and guidance, and developed a design with sufficient built-in diversity to meet USNRC DI&C ISG-02 Staff Position 1 without a Diverse Actuation System (DAS).

Key Words: Digital, RPS, RTS, ESFAS, CCF, Diversity, Defense-in-Depth

1 INTRODUCTION

Diablo Canyon Power Plant (DCPP) is replacing the existing digital Westinghouse Eagle 21 Process Protection System (PPS) to address maintenance and obsolescence issues. The Eagle 21 PPS was installed in 1994 to replace the original analog Westinghouse 7100 PPS. The analog PPS possessed design depth

and diversity such that two or more diverse protective actions would terminate an accident before consequences adverse to public health and safety could occur [1]. The Eagle 21 PPS met the requirements for D3 that existed at the time it was licensed; however, manual operator action was credited for several mitigation scenarios where both primary and backup protection functions were performed in the Eagle 21 PPS.

The current USNRC staff position regarding manual operator action credited in D3 evaluations is set forth in Interim Staff Guidance (ISG)-02 [4] as follows:

“(1) When an independent and diverse method is needed as backup to an automated system used to accomplish a required safety function, the backup function can be accomplished via either an automated system, or manual operator actions performed in the main control room. The preferred independent and diverse backup method is generally an automated system. The use of automation for protective actions is considered to provide a high-level of licensing certainty....

“(2) If automation is used as the backup, it should be provided by equipment that is not affected by the postulated RPS CCF and should be sufficient to maintain plant conditions within BTP 7-19 recommended acceptance criteria for the particular anticipated operational occurrence or design basis accident...

“(3) If manual operator actions are used as backup, a suitable human factors engineering (HFE) analysis should be performed to demonstrate that plant conditions can be maintained within BTP 7-19 recommended acceptance criteria for the particular anticipated operational occurrence or design basis accident...

Using the guidance of DI&C ISG-02, PG&E reviewed the DCPD Final Safety Analysis Report (FSAR) [3] Chapter 15 licensing basis accident analyses and the Nuclear Regulatory Commission (NRC) Eagle 21 Safety Evaluation Report (SER) [5] in accordance with USNRC Branch Technical Position (BTP) 7-19 [6]. The review considered the CCF to cause failure of the entire Process Protection System (PPS) concurrent with each Chapter 15 event and accident for which primary or backup mitigative action by the PPS was credited in the analysis. The goals of the review were (a) to identify available automatic means to prevent concurrent PPS software CCF from adversely affecting the mitigation of FSARU Chapter 15 accident or events; and (b) to develop a coping strategy without crediting manual operator actions to mitigate events where diverse automation sufficient to meet Positions (1) and (2) did not exist outside the existing PPS. PG&E considered that the Human Factors Evaluation (HFE) study to demonstrate adequate operator response per Position (3) presented an unacceptable degree of project risk with respect to the additional Staff review time that would be required for evaluation and, for lack of a precedent, the potential uncertainty of the outcome.

2 ASSESSMENT PROCESS

The DCPD digital PPS replacement D3 assessment describes the integrated digital PPS system design proposed for the replacement. The assessment describes the diversity between the PPS software and the plant control systems, indications, alarms and readouts, and manual circuitry. The assessment evaluated design-basis transients and accidents with the assumed concurrent CCF to demonstrate that plant responses to these transients and accidents can successfully comply with the defined acceptance criteria. Diverse systems and/or operator actions required to meet acceptance criteria were noted.

The evaluation comprised three basic tasks:

1. Identification of the set of transients and accidents to be considered in combination with the assumed CCF of the digital PPS.

2. An evaluation of these transients and accidents which could challenge BTP 7-19 acceptance criteria given a CCF of the PPS; that is, where primary and backup protection functions resided entirely in the existing PPS, thus potentially susceptible to the postulated CCF.
3. Determination of a coping strategy to address the events where BTP 7-19 acceptance criteria could be challenged given a design basis accident or event with a concurrent CCF to the PPS.

The first two tasks identify the FSAR Chapter 15 design basis events to be considered. Each design basis accident or event in the existing FSAR analyses was then screened for one of the following four categories based on the assumption of PPS failure due to CCF:

- Category 1: Events that do not require the PPS for primary or backup protection
- Category 2: Events that do not require the PPS for primary but require the PPS for backup protection
- Category 3: Events that require the PPS for primary protection but also receive automatic backup protection from systems other than the PPS
- Category 4: Events that assume the PPS for primary and backup protection signals for some aspect of the automatic protection

The events of the first three categories required no further analysis because the postulated concurrent CCF will not adversely affect event mitigation. The remaining Category 4 events are potentially challenging to BTP 7-19 acceptance criteria and require further analysis with respect to the coping strategy.

2.1 Replacement PPS Architecture to Support the D3 Assessment

The PPS Replacement Project replaces in its entirety the Westinghouse Eagle 21 PPS hardware as illustrated in the shaded portion of Figure 1. Equipment in the unshaded portion of Figure 1 is not being replaced or modified by this project. Thus, the PPS Replacement Project maintains the Westinghouse 4-channel, 2-train architecture without affecting existing diverse systems (Nuclear Instrumentation System, ATWS Mitigation System, and Solid State Protection System).

Figure 2 illustrates a typical allocation of the specific signals used to implement Reactor Trip System (RTS) and Engineered Safety Feature (ESF) functions between the Triconex Tricon and the Westinghouse Advanced Logic System (ALS) portions of the PPS replacement for one of the four (4) redundant replacement Protection Sets. The existing Nuclear Instrumentation System (NIS) and the AMSAC illustrated in Figure 2, and Class II signals from turbine controls and RCP switchgear not shown in Figure 2 provide diverse protection not subject to CCF, and are not affected by the PPS replacement.

PPS replacement functions are implemented in the same four (4) redundant Protection Sets as the existing Eagle 21 PPS. Each Protection Set uses a software-based Triconex Tricon programmable logic controller (PLC) described in Tricon V10 Topical Report Submittal [10] to mitigate events automatically where the PPS Replacement D3 Assessment determined that existing diverse and independent automatic mitigating functions are available to mitigate the effects of postulated CCF concurrent with FSAR [3] Chapter 15 events that were credited with automatic mitigation. For the events where this assessment determined that additional diversity measures outside the existing PPS were necessary to preclude manual mitigative action, automatic protective functions are performed in the diverse safety-related ALS shown in the shaded portion of Figure 1. The ALS is described in the ALS Topical Report Submittal [11].

The decision to provide diverse automatic protection functions where the existing Eagle 21 PPS relied on manual action by the operator in event of a protection system CCF concurrent with a design basis event was based on the current USNRC Staff position regarding backup systems or actions necessary to perform safety functions. Section 1 of this paper summarizes the Staff position.




Figure 1: Simplified Diablo Canyon Process Protection System Replacement





Figure 2. Typical Replacement Process Protection Set

PG&E considered that the Human Factors Evaluation (HFE) study necessary to demonstrate adequate operator response per Position (3) presented an unacceptable degree of project risk with respect to the additional Staff review time that would be required for evaluation and the potential uncertainty of the outcome. Therefore, PG&E developed a coping strategy that did not credit manual operator actions to mitigate events where diverse automation sufficient to meet above Positions (1) and (2) did not exist outside the existing PPS. The improved licensing certainty outweighs the scope added by the selected approach.

The Tricon is Triple Modular Redundant (TMR) from input terminal to output terminal, each input and output module includes three separate and independent input or output circuits or legs. Refer to Figure 3. These legs communicate independently with the three Main Processor modules. Standard firmware is resident on the Main Processor modules for all three microprocessors as well as on the input and output modules and communication modules, which are not shown in the figure. The TMR architecture allows the Tricon to detect individual faults on-line, and maintain operation without interruption of monitoring, control, and protection capabilities. In the presence of a fault, the Tricon alarms the condition, removes the affected portion of the faulted module from operation, and continues to function normally in a dual redundant mode. The system returns to the fully triple redundant mode of operation when the affected module is replaced.




Figure 3. Simplified Tricon Triple Modular Redundant Architecture

Automatic protective functions will be performed in a diverse Class IE ALS for events where existing analyses credit manual action to mitigate events that occur with a concurrent CCF to the PPS. The generic ALS internal architecture is illustrated in Figure 4. The diverse ALS portion of the PPS replacement platform utilizes Field Programmable Gate Array (FPGA) hardware logic rather than a microprocessor and has no software component required for operation of the system, although software-based tools are used in FPGA design and implementation. The NRC noted in the SER [12] for the much simpler FPGA-based Wolf Creek Nuclear Operating Company Main Steam and Feedwater Isolation System states that it is a unique application, and future ALS applications, such as an RPS or ESFAS (i.e., the DCCP PPS Replacement) that receives input signals and makes trip decisions, may require additional design diversity.

Concern for ALS software CCF is addressed in the PPS replacement through incorporating additional, built-in, design diversity in the FPGA-based hardware system and using qualified design practices and methodologies to develop and implement the hardware. The ALS subsystem provides two complete and diverse execution paths “A” and “B” with independent design and V&V teams for the Core Logic Boards (CLB), input boards and output boards as shown in Figure 5.




Figure 4. Generic Advanced Logic System Architecture




Figure 5 ALS Diversity Architecture for DCPD PPS Replacement

Appropriate V&V activities ensure that the output from each development team is indeed diverse from the other. Each CLB has its own set of input and output boards (“A” for CLB “A” and “B” for CLB “B”). The diverse execution path outputs are combined in hardwired logic to ensure that the protective action is taken if directed by either path. A single failed path cannot prevent a protective action. Additional information regarding ALS diversity is provided in the ALS Topical Report [11] and Diversity Analysis [13].

Each FPGA core in an execution path contains two sets of redundant hardware logic (“A1” & “A2”; “B1” & “B2”), which perform the application-specific functions independently and in parallel. Diversity between the two sets of logic within the FPGA is achieved by changing the logic implementation during

the synthesis process. A CLB that detects a mismatch between its logic core outputs identifies itself as failed and sets its outputs to a fail-safe state before halting operation.

The ALS provides signal conditioning for the Pressurizer Vapor Space temperature, RCS wide range temperature and narrow range RTD inputs to the OPDT and OTDT thermal trip functions. These safety-related temperature signals are passed via analog signals from the ALS to the Tricon for processing by the Tricon portion of the PPS replacement. There is no digital communication of safety-related information from the software-based Tricon to the logic-based ALS. There is no software-based communication between or among redundant or diverse Protection Sets. No database information or equipment that uses software is shared between the Tricon and the diverse ALS or between redundant Protection Sets within Tricon or ALS portions of the replacement PPS, except for the analog temperature signals discussed above.

The built-in diversity of the ALS subsystem ensures that the PPS replacement will perform the required safety functions automatically in the presence of a postulated Tricon CCF without an adverse impact on the operator's ability to diagnose the event or perform previously credited manual actuation activities. A Tricon CCF cannot affect ALS safety function.

The built-in diversity provided by the "A" and "B" ALS execution paths prevents both "A" and "B" paths from being disabled by the same CCF. In other words, a CCF may be assumed that causes the "A" ALS execution path to fail, but the unaffected "B" ALS execution path will remain functional. Conversely, a CCF may be assumed that causes the "B" ALS execution path to fail, but the unaffected "A" ALS execution path will remain functional.

2.2 D3 Assessment

The DCPD D3 assessment assumed that a worst-case CCF results in a total failure of the Tricon portion of the PPS system, similar to the Eagle 21 D3 evaluation. The Eagle 21 diversity assessment assumed a postulated CCF caused all automatic protection functions generated in the Eagle 21 PPS to fail to perform the protection functions described in DCPD FSAR Chapter 15.

Category 1 protection functions in Table I are processed through systems other than the PPS. The FSAR Chapter 15 analysis of the events crediting these independent and diverse protective functions either: (1) takes credit for independent primary mitigating functions; or (2) does not require a primary mitigating function. Mitigation of these D3 Assessment Category 1 events is unaffected by CCF of the PPS.

Category 2 and 3 protection functions in Table II either: (1) do not require the PPS for primary protection but assume PPS for backup protection (Category 2); or (2) require the PPS for primary protection but receive automatic backup protection from systems other than the PPS (Category 3). These protection functions are performed in the software - based Tricon subsystem of the replacement PPS. Independent and diverse primary or backup protection is available for these functions. Mitigation of these Category 2 and 3 events is not adversely affected by CCF of the PPS Tricon subsystem.

Category 4 protection functions require the PPS for both primary protection and backup protection. Manual operator action is credited in the existing Eagle 21 SER to mitigate these events given a concurrent CCF in the PPS. In the replacement PPS, these protection functions are performed in the logic based ALS subsystem of the replacement PPS where built-in diversity ensures continued automatic protection given a concurrent CCF. Mitigation of Category 4 events is not affected by CCF of the PPS Tricon or ALS subsystem. The ALS is not affected by a Tricon CCF. The ALS "A" and "B" execution paths are not disabled by the same CCF.

Table I. Functions Not Processed in the PPS

| Process Variable | D3 Assessment Category 1 Protection Functions |
|------------------------------------|--|
| Neutron Flux | Power Range High-Flux (Low Setting) Reactor Trip |
| | Power Range High-Flux (High Setting) Reactor Trip |
| | Power Range Positive Flux Rate Reactor Trip |
| | Power Range Flux Control Rod Stop |
| | Intermediate Range High-Flux Reactor Trip |
| | Source Range High-Flux Reactor Trip |
| | Input to Over Power Delta Reactor Trip |
| | Input to Over Temperature Delta T Reactor Trip |
| AMSAC(Steam Generator Low Level) | Turbine Trip Above C-20 Permissive |
| Main Turbine Stop Valve Position | Turbine Trip Reactor Trip |
| Turbine Auto Stop Oil Pressure Low | |
| RCP Bus Undervoltage | Reactor Trip |
| RCP Bus Underfrequency | Reactor Trip |
| RCP Circuit Breaker Open | Reactor Trip |

Table II. Functions That Assume PPS for Automatic Backup Protection or That Receive Automatic Backup Protection from Another System if PPS is Primary

| Process Variable | D3 Assessment Category 2 and 3 Protection Functions |
|------------------------------|--|
| Pressurizer Level | Pressurizer High-Level Reactor Trip |
| RCS Narrow-Range Temperature | Input to Over Temperature Delta T Reactor Trip |
| | Input to Over Power Delta T Reactor Trip |
| | Input to SG Low-Low Level Trip Time Delay |
| Steam Generator Level | Steam Generator Low-Low Level Reactor Trip |
| | Hi-Hi Level Feedwater Isolation |
| | Hi-Hi Level Turbine Trip |
| | Hi-Hi Level MFW Pump Trip |
| | Low-Low Level AFW Actuation (Process Sense performed by RTS; AMSAC utilizes independently isolated level signals and independent turbine impulse pressure channels to provide diverse function) |
| Steam Line Pressure | High-Negative Pressure Rate SLI |
| | Low-Pressure SI |
| | Low-Pressure SLI |
| Turbine Impulse Pressure | Permissive 13 Low Turbine Power Permissive (Input to P-7 Low Power Reactor Trip Permissive) |

Table III shows how the PPS functions automatically performed by the diverse ALS subsystem preclude the manual operator actions otherwise required to mitigate events in the presence of a concurrent CCF. Each of the Category 4 events listed in the left hand column required manual operator action for accident mitigation in the presence of a CCF in the Eagle 21 PPS SER [5]. The "X" in the associated PPS

function column identifies the ALS functions that will remain operational due to the built-in diversity characteristics of the ALS system. The need for manual operator action is eliminated by the diversity built into the replacement PPS design and plant safety is improved without the need for a DAS.

Table III. Functions That Assume PPS for Primary and Backup Protection

| Accident Analysis/Event | | D3 Assessment Category 4 Protection Functions | | | | | | | |
|-------------------------|-------------------------------------|---|----------------------|---------------------|------------------------|-------------------------|-------------------------|---------------------------------------|-----------------|
| FSAR Section | D3 Topical Report Category 4 Events | PZR Pressure Low SI (Note 1) | PZR Pressure High RT | PZR Pressure Low RT | Cont. Pressure High SI | Cont. Isolation Phase A | Cont. Isolation Phase B | Cont. Pressure High Containment Spray | RCS Flow Low RT |
| 15.2.5 | Loss of Forced RCS Flow | | | | | | | | X |
| 15.2.13 | RCS Depressurization | | | X | | | | | |
| 15.3.1 15.4.1 | SBLOCA / LBLOCA | X | | X | X | X | X | X | |
| 15.4.2.1 | Steam Line Break | X | | | | X | X | X | |
| 15.4.2.2 | Main Feed Pipe Rupture | | X | | X | X | | | |
| 15.4.3 | SG Tube Rupture | X | | X | | | | | |

Note 1: Automatic reactor trip occurs on safety injection due to low pressurizer pressure or high containment pressure.

The NRC Staff determined in the D3 SER [8] that the Class IE, nuclear safety-related DCPD replacement PPS design adequately addresses the ISG-02 Staff Positions and will meet BTP 7-19 acceptance criteria without a Diverse Actuation System (DAS) should a CCF occur in either the Tricon or ALS subsystems of the PPS system concurrent with the events for which automatic mitigation by the PPS is now credited. Since that review, ISG-02 has been incorporated into Revision 6 of BTP-19 [11].

3 CONCLUSIONS

Diablo Canyon Units 1 and 2 FSARU Chapter 15 licensing basis accident analyses were reviewed to determine which events required the Eagle 21 Process Protection System for primary or backup protection. Those transients identified as requiring the Process Protection System for primary protection system response were reviewed to determine the availability of diverse means of automatically mitigating the transient are available, or annunciators and indicators to allow the operator to diagnose the event and bring the plant to a safe shutdown condition in a timely manner. However, each of the eight Category 4 functions shown in Table III would be rendered inoperable due to the effects of a postulated CCF under the existing Eagle 21 diversity scheme [5], because both primary and backup protection functions are performed by the Eagle 21 PPS. Operator action would be required to mitigate the events. The replacement PPS design, which incorporates the safety-related ALS subsystem with built-in system diversity, will ensure that these functions will be performed automatically without adverse impact to the operator's ability to diagnose or perform previously credited manual actuation activities. A Diverse Actuation System (DAS) is not required.

After several false starts due to uncertainty in the approach (which consumed about 2 years, and which DI&C ISG-06 helped resolve, as discussed in another paper presented at this conference [14], the D3 assessment was completed in about 1 year. PG&E submitted the PPS Replacement Project D3 Assessment Topical Report to NRC in April, 2010 [7], and revised it in September, 2010 [8] to incorporate responses to Requests for Additional Information (RAI). PG&E received NRC approval of the D3 Topical Report in April, 2011 [9]. The License Amendment for replacement of the Eagle 21 PPS was submitted to NRC on October 26, 2011, and NRC has nearly completed the Safety Evaluation. The

development process took place in 2011-2014 with some back and forth iteration between requirements and design phases due to interpretation of the requirements specifications, also discussed in Reference 14. Approval of the License Amendment is expected in late 2015.

4 ACKNOWLEDGEMENTS

Scott Patterson, PG&E Gregg Clarkson, Rock Creek Technology Larry Erin, Westinghouse
Mike Phillips, Invensys Steen Sorenson, CS Innovations

5 REFERENCES

1. Westinghouse Electric Corporation WCAP-7306, "Reactor Protection System Diversity in Westinghouse Pressurized Reactors," (1969) Non-Proprietary Class 3.
2. Title 10 Code of Federal Regulations Article 50.62, "Requirements for Reduction of Risk from Anticipated Transients without Scram (ATWS) Events for Light-Water-Cooled Nuclear Power Plants," January, 2003.
3. Diablo Canyon Power Plant Final Safety Analysis Report (FSAR).
4. U.S. Nuclear Regulatory Commission, Digital Instrumentation and Controls, Revision 2, "DI&C-ISG-02 Task Working Group #2: Diversity and Defense-in-Depth Issues Interim Staff Guidance," June 5, 2009, ADAMS Accession No. ML091590268
5. USNRC, "Safety Evaluation Report Eagle 21 Reactor Protection System Modification With Bypass Manifold Elimination, PG&E, Diablo Canyon Power Plant, " (October 7, 1993).
6. USNRC Branch Technical Position (BTP) 7-19, Rev 6, "Guidance for Evaluation of Defense-in-Depth and Diversity in Digital Computer-Based Instrumentation and Control Systems," July, 2012, ADAMS Accession Number ML110550791
7. PG&E, "Review of Diablo Canyon Power Plant Topical Report, Process Protection System Replacement Diversity and Defense-in-Depth Assessment, April 9, 2010, ADAMS Accession Number ML101100646
8. PG&E, "Diablo Canyon Power Plant Topical Report, Process Protection System Replacement Diversity & Defense-in-Depth Assessment," September 9, 2010, ADAMS Accession No. ML102580726
9. U.S. Nuclear Regulatory Commission, Letter "Diablo Canyon Power Plant, Unit Nos. 1 and 2 - Safety Evaluation for Topical Report, "Process Protection System Replacement Diversity & Defense-In-Depth Assessment" (TAC Nos. ME4094 and ME4095)," April 19, 2011, ADAMS Accession No. ML110480845
10. Invensys Operations Management, Topical Report 7286-545-1, Revision 4, "Triconex Topical Report," December 20, 2010, ADAMS Accession No. ML110140443
11. CS Innovations Document No. 6002-00301-NP, Revision 1, "ALS Topical Report and Supporting Documents Submittal," August 11, 2010, ADAMS Accession No. ML102570797
12. NRC, Safety Evaluation Report Wolf Creek Nuclear Operating Company (WCNOC) Main Steam and Feedwater Isolation System (MSFIS), ADAMS Accession Number ML090610317.
13. CS Innovations, Document No. 6002-00031, Revision 1, "ALS Diversity Analysis," July 29, 2010, ADAMS Accession No. ML102160479
14. K.J. Schrader, J.W. Hefler, E.L.Quinn, "Diablo Canyon Power Plant Digital Process Protection System Replacement Licensing Experience Using ISG-06," *NPIC-HMIT*, Charlotte, NC, February 22-26, 2015, Paper #12017.